



Annual Summary Monitoring Data

Licence Details: Caltex Banksmeadow Terminal, Penrhyn Rd, Banksmeadow NSW, 2019, EPL # 6950

EPA Point		Point 1: Discharge to Waters					Reason for Missing Data	Publishing Date
Pollutant	pH	Volume	Oil and Grease	Total Suspended Solids	Biochemical oxygen demand			
Licence Limit	6.5 - 8.5	1728	10	30	20			
Unit of Measure	pH Unit	kL/day	mg/l	mg/l	mg/l			
Monitoring Frequency Required by Licence	Daily during discharge	Daily during discharge	Daily during discharge	Daily during discharge	Daily during discharge			
Reporting Period	Averaging Period	N/A	N/A	N/A	N/A			
1/04/2016-31/03/2017	No. Samples Collected	1	1	1	1	No missing data	09-Apr-18	
	Lowest	6.8	511	<5	7.0			<5
	Mean	6.8	511	<5	7.0			<5
	Highest	6.8	511	<5	7.0			<5
	Exceedance (yes/no)	No	No	No	No			No

Caltex has prepared this information in good faith exercising all due care and attention, but no representation or warranty, express or implied is made as to the relevance, accuracy, completeness or fitness for purpose of this information in respect of any particular user's circumstances. Provision of this information does not constitute an opinion or interpretation by Caltex of the information and users of this information should satisfy themselves concerning its application to, and where